



**WALKER SPECIALTY
CONSTRUCTION INC.**

February 10, 2006

Juanita Point Condos LLC
Creative Contracting
4008 37th Ave SW
Seattle, WA. 98128
Attn: Hollis Beebe

RE: Juanita Point – Residence Abatement
9119 Juanita Dr. Kirkland, WA.

Dear Hollis:

Walker Specialty Construction has completed abatement of the asbestos containing materials, identified in the NVL Labs asbestos survey dated 1/16/06 at the above referenced project.

Please let this letter serve as confirmation that the following asbestos containing materials have been removed and disposed of in accordance with all regulatory agency requirements. Copies of permits, air monitoring, and waste disposal manifests will be forwarded as soon as they are received by Walker Specialty Construction unless they are enclosed.

As identified in survey dated 1/16/06.
Approximately 200 SF VAT, 10 SF of duct paper/tape, and approx.
330 SF of roofing materials.

If you have any questions, please call me at 425/806-7377.

Sincerely,

Paul Wolf
Project Manager

PO. Box 469 • Snohomish, WA 98291-0469 • (206) 361-8913 • (360) 805-0354 • FAX (425) 806-7383

Environmental Contractors - Asbestos & Lead Abatement

Urethane Foam Insulation • Fireproofing • Fluid Applied Coatings

AIR SAMPLE DATA SHEET

BATCH ID
2601568.00

1 Hr Rush Clearance
1 Day on others

Page 1 of 1

(206)361-8913, (360)805-0354, FAX (425)806-7383
GC#WALKES0549, Asbestos Cert. #01198

Job Number A3561
Client Job Number _____
Number of Samples 4

Client: Juanita Point Condos
Location: 9119 Juanita Dr. Seattle

Abatement Firm: Walker Spec Const.
Results to: Fibers () () ()

Sampled by: John Jones
Company: Walker Spec Const.
Received by: Emily Maguire - NR
Analyzed by: [Signature]

Date: 2-3-06
Blank Cassettes: _____
Blank count: _____ (AVG.)
Date: 2/3 12:30pm
Date: 2/6 10:35AM

Microscope filed area: _____
Filter size: (circle one) 25mm or 37mm

Sample ID: <u>A1</u>	Location: <u>Furnace Room</u>	Observations: <u>wet method VAC, VENT PIPE w/ PAPER REMOVAL</u>
Sample Type: <u>PCC</u>	Worker: _____	SS#: _____ Cert #: _____
Protection: <u>m</u>	Time: Start <u>9:41</u>	Rate: Start <u>12</u> Fibers/Fields
Decon: <u>N/A</u>	End <u>10:21</u>	End <u>12</u> Fibers/Fields
Environment: <u>H</u>	Minutes = <u>100</u>	Average = <u>12</u> Liters <u>1200</u> Fields <u>1/100</u> CC <u><0.002</u>
Pump #: <u>L</u>		
Sample ID: <u>P2</u>	Location: <u>SAME AS ABOVE</u>	Observations: <u>SAME AS ABOVE</u>
Sample Type: <u>B</u>	Worker: <u>John Jones</u>	SS#: _____ Cert #: <u>06/0408</u>
Protection: <u>m</u>	Time: Start <u>8:50</u>	Rate: Start <u>2.5</u> Fibers/Fields
Decon: <u>N/A</u>	End <u>9:48</u>	End <u>2.5</u> Fibers/Fields
Environment: <u>H</u>	Minutes = <u>58</u>	Average = <u>2.5</u> Liters <u>145</u> Fields <u>4.5/100</u> CC <u><0.019</u>
Pump #: <u>2</u>		
Sample ID: <u>P2</u>	Location: <u>SAME AS ABOVE</u>	Observations: <u>SAME AS ABOVE</u>
Sample Type: <u>C</u>	Worker: _____	SS#: _____ Cert #: _____
Protection: <u>m</u>	Time: Start <u>9:48</u>	Rate: Start <u>2.5</u> Fibers/Fields
Decon: <u>N/A</u>	End <u>10:18</u>	End <u>2.5</u> Fibers/Fields
Environment: <u>H</u>	Minutes = <u>30</u>	Average = <u>2.5</u> Liters <u>75</u> Fields <u>1/100</u> CC <u><0.020</u>
Pump #: <u>2</u>		
Sample ID: <u>A2</u>	Location: <u>SAME AS ABOVE</u>	Observations: <u>SAME AS ABOVE</u>
Sample Type: <u>CL</u>	Worker: _____	SS#: _____ Cert #: _____
Protection: <u>m</u>	Time: Start <u>10:21</u>	Rate: Start <u>12</u> Fibers/Fields
Decon: <u>N/A</u>	End <u>12:01</u>	End <u>12</u> Fibers/Fields
Environment: <u>H</u>	Minutes = <u>100</u>	Average = <u>12</u> Liters <u>1200</u> Fields <u>2/100</u> CC <u><0.002</u>
Pump #: <u>1</u>		
Sample ID: _____	Location: _____	Observations: _____
Sample Type: _____	Worker: _____	SS#: _____ Cert #: _____
Protection: _____	Time: Start _____	Rate: Start _____ Fibers/Fields
Decon: _____	End _____	End _____ Fibers/Fields
Environment: _____	Minutes = _____	Average = _____ Liters _____ Fields _____ CC _____
Pump #: _____		

154
2/3
12:35

Sample Types

Control Choices

- B-Breathing Zone
- TWA
- A-Area
- I-Inside reg area
- O-Outside reg area
- P-Pre Abatement
- CL-Clearance
- X-Aggressive
- H-HEPA exhaust
- C-Ceiling
- BL-Field Blank

- Respiratory Protection: PA-Pressure Demand Air, CA-Continuous Flow Air, PAPP, F-Full Face Mask APR, M-Half Mask APR
- Decontamination: D,S-Decon w/Shower, O-Decon w/o Shower
- Environment: H-HEPA Vacuum, N-Negative Air, G-Glovebag

MSC Job # 1341

Cont # _____

PSCAA # _____

RABANCO

WASTE SHIPMENT RECORD

CONTAINER ACTIVITY RECORD SITE	1. Waste Generated Site Name and Address: <i>1100 Duane St. DOGSEA CO</i>		Owner's Name: <i>DOGSEA CO</i>		Owner's Phone No.:		
	2. Operator's Name and Address: WALKER SPECIALTY CONSTRUCTION, INC. PO BOX 469, Snohomish, WA 98291-0469				Operator's Phone No.: (206) 361-8913		
	3. Waste Disposal Site (WDS) Name and Address, and Physical Site Locations: Roosevelt, WA 99356				WDS Phone No.:		
	4. Responsible Local, State or EPA Agency Name and Address: PUGET SOUND CLEAN AIR AGENCY 110 Union Street, Suite 500, Seattle, WA 98101						
	5. Description of Waste Materials:		6. Containers		7. Total Quantity		
	<i>Asbestos Containing Materials</i>		No.	Type	m ³	(yd ³)	
			<i>3</i>	<i>MEGA BOX</i>		<i>6</i>	
			<i>1</i>	<i>Barrel</i>		<i>1/2</i>	
	8. Special Handling instructions and Additional Information: <p style="text-align: center;">DOUBLE BAGGED & LABELED</p>						
	9. OPERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully accurately described above by proper shipping name and are classified, packed, marked and labeled, and are in all respects in proper condition for transport by highway according to applicable International and government regulations.						
	Printed/typed Name <i>John Jones</i>		Signature <i>[Signature]</i>		Month <i>5</i>	Day <i>3</i>	Year <i>2007</i>
	10. Transporter 1 Acknowledgment of Receipt of Materials						
	Printed/typed Name <i>John Hamill</i>		Signature <i>[Signature]</i>		Month <i>5</i>	Day <i>3</i>	Year <i>2007</i>
11. Transporter 2 Acknowledgment of Receipt of Materials							
Printed/typed Name Rabanco Transfer 2733 3rd Ave. S. Seattle, WA 206-646-2565		Signature		Month	Day	Year	
12. Discrepancy Indication Space Waste Disposal RRLC							
13. Authorized Waste Disposal Site Owner or Operator: Certification of receipt of asbestos materials covered by this manifest except as noted in item 12							
Printed/typed Name		Signature		Month	Day	Year	

